



MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT, WEST ZONE
DR. SAHIB SING VERMA NIGAM BHAWAN
SHIVAJI ENCLAVE, RAJA GARDEN, NEW DELHI - 110027



No.DHO/WZ/2023/D- 688

Dated: 07/06/23

HEALTH CERTIFICATE

1. Name of the School VEDA VYASA D.A.V. PUBLIC SCHOOL
2. School address D-Block Vikaspuri, New Delhi-110018
3. No of shifts 01 (Morning) Timing 08:00 AM TO 2.00PM
4. No of students:- Boys 2331 Girls 1735 Total 4066
5. No of staff: - Gents 12 Ladies 110 Total 122

Accommodation provide for classroom as under:-

- Floor area in the classroom is sufficient /insufficient Sufficient
- Classes are well lighted/ ill lighted Well lighted
- Classrooms are well ventilated/ill ventilated Well ventilated
- Classes are kept/ not kept neat and clean Neat & clean
- Building/ classrooms require/ do not require white wash etc. Not required
- Drinking water is wholesome/ not wholesome Wholesome
- Latrine arrangement is sanitary/ insanitary Sanitary from health point of view

Note:- Valid for one year from the date of issue

07.6.23

Dy. Health Officer
West Zone

Dy Health Officer
West Zone
MCD

"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"



DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT NANGLOI , DELHI-110041

आज़ादी का
अमृत महोत्सव

Water sample collected from " Veda Vyasa D.A.V. Public School" D Block, Vikaspuri, New Delhi -110018
vide challan No- 43 Dated-08.05.2023.

S. No	Parameter	Units	Limit		S1
			Acceptable	Permissible	
PHYSICAL EXAMINATION					
1.	Date of collection	-----	--	--	24.05.2023
2.	Date of Analysis	-----	--	--	25.05.2023
3.	Colour	Hazen	5.0	15	Clear
4.	Odour	-----	No. Objectionable		No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	1.18
6.	PH value	-----	6.5	8.5	7.40
7.	Electrical Conductivity	µmho	--	--	226
8.	Total dissolved solids	mg/l	500	2000	146.9
CHEMICAL EXAMINATION					
9.	P th Alkalinity	mg/l	--	--	NIL
10.	Total Alkalinity	mg/l	200	600	86
11.	Total Hardness	mg/l	200	600	110
12.	Calcium Hardness	mg/l	--	--	84
13.	Magnesium Hardness	mg/l	--	--	26
14.	Calcium as Ca	mg/l	75	200	33.6
15.	Magnesium as Mg	mg/l	30	100	6.24
16.	Ammonia as N	mg/l	0.5	N.R.	NIL
17.	Nitrite as N	mg/l	--	--	NIL
18.	Nitrate as NO ₃	mg/l	45	N.R.	2.6
19.	Sulphate	mg/l	200	400	30
20.	Chloride	mg/l	250	1000	18
21.	Dissolved Iron	mg/l	0.3	N.R.	0.04
22.	Fluoride	mg/l	1	1.5	0.16
23.	Cyanide	mg/l	0.05	N.R.	ND
24.	Residual Chlorine	mg/l	0.20	1.0	NIL
BACTERIOLOGICAL EXAMINATION					
25.	Coli-form per 100 ml at 37°C	MPN	0		0

REMARKS : As per tested parameters sample -S1 can be use for drinking purpose.

S. S. S. S.
Chemist

S. S. S. S.
05/06/23
ACWA
Asstt. Chief Water Analyst
DELHI JAL BOARD
Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Works Nangloi, Delhi-41